WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 104531
Permit No.
Basin 212

NOTICE OF INTENT NO. 34558 41

1. OWNER Spring Oaks Retail center
MAILING ADDRESS 1230 Montana Ave #202 Santa Monica, CA A. 90403-5987
ADDRESS AT WELL LOCATION 4755 W. Spring Mountain Las vegas, NV 89102

2. LOCATION SW ¼ NW ¼ Sec. 18 T. 21 N/S R. 61 E. Clark County
PERMIT NO. Issued by Water Resources | Parcel No. 162-18-201-004 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG PMW-19

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Asphault | | 0 | 6" | .5 |
| Type II | | 6" | 2' | 1.5 |
| sandy clay | | 2' | 15 | |
| caliche | | 15 | 17 | |
| clay | | 17 | 43 | |
| caliche | 38 | 43 | 45 | |
| clay | | 45 | 49 | |
| caliche | | 49 | 50 | |
| UTME | | 5,399.6 | | |
| UTMN | | 4,886.4 | | |

Date started 10-17, 2007
Date complated 10-17, 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 50 Feet Depth Cased 50 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 9 Inches | | 0 Feet | 50 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4" | PVC | Sch 40 | 0 | 50 |
| | | | | |

Perforations:
Type perforation Factory slot
Size perforation .020
From 30 feet to 50 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 27 to 25 bentonite
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 27 feet to 50 feet

9. WATER LEVEL
Static water level 38' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Elite Drilling Inc. Contractor
Address 4255 W. Post rd. Contractor
Lasvegas, NV 89118
Nevada contractor's license number issued by the State Contractor's Board 0054931
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869
Signed By driller performing actual drilling on site or contractor
Date 10/23/07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627