

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 104544
Permit No. _____
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33005

1. OWNER Trox LLC ADDRESS AT WELL LOCATION 8000 W Lake Mead Pkwy
 MAILING ADDRESS Po Box 268859 win corp co. Henderson, NV
Oklahoma City, OK - 73126 Subdivision Name: _____ County: Clark

2. LOCATION NE 1/4 SW 1/4 Sec 12 T 22 N R 62 E Latitude 36 02 54 N UTM E NAD 27
 PERMIT/WAIVER No. H000 539 178-12-301-003 Longitude 115 00 18 W N NAD 83/WGS 84
 Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test Monitor Stock
 Municipal/Industrial

5. WELL TYPE
 Cable Rotary RVC
 Air Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Silty Gravelly Sand</u>		<u>0'</u>	<u>18.5</u>	<u>18.5</u>
<u>very Silty Sand</u>		<u>18.5</u>	<u>21.5</u>	<u>3'</u>
<u>Silty sandy Gravel w/calcite</u>		<u>21.5</u>	<u>22.5</u>	<u>1'</u>
<u>Silty Gravelly Sand</u>		<u>22.5</u>	<u>27.5</u>	<u>5'</u>
<u>Gravelly sand</u>		<u>27.5</u>	<u>30</u>	<u>2.5</u>
<u>Clayey silt and silt</u>	<u>X</u>	<u>30</u>	<u>47</u>	<u>17</u>

9. WELL CONSTRUCTION
 Depth Drilled 47 Feet Depth Cased 47 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 47
10 Inches 0 Feet 47 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6"</u>	<u>Sch 40</u>	<u>.56</u>	<u>24</u>	<u>0</u>
<u>6"</u>	<u>Sch 40</u>	<u>.56</u>	<u>46'</u>	<u>44</u>

Perforations:
 Type of perforation factory
 Size of perforation 0.20
 From 44 feet to 24 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Annular Seal: Yes No
 Neat Cement 14 to 2 Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 ≥30% Bentonite Grout _____ to _____ Pumped Poured
 Gravel Pack: Yes No 44 to 19 Pumped Poured
 Type: #3 Sand
 Bentonite Chips: Yes No 19 to 14 Pumped Poured
 Type: 3/4 Hole Plug

7. Water Level
 Static water level: 30.41 feet below land surface
 Artesian Flow: _____ G.P.M. _____ P.S.I.
 Water Temperature: _____ °F
 Quality: _____

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

DCNR/DWR RECEIVED
JAN 03 2008

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Dennis Ree Boast Longyear Contractor
 Address 7773 W Seldon Ln. Contractor
Peoria, AZ 85345
 Nevada contractor's license number _____
 issued by the State Contractor's Board 0010157
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2250
 Signed Dennis R Reed
 By driller performing actual drilling on site or contractor
 Date _____