TT806 - MW03

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 104617
Permit No.
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 54767

1. OWNER DEPT OF NAVY NAS FALLON
MAILING ADDRESS 4755 Pasture Rd
ADDRESS AT WELL LOCATION 4755 Pasture Rd.
Fallon, NV. 89496
Subdivision Name: NAS FALLON County: Churchill

2. LOCATION ~~NE~~ SE ¼ SW ¼ Sec 22 T 18 N/S R 29 E
Latitude
Longitude
UTM E 1150351833 ☐ NAD 27
N 4363129 ☒ NAD 83/WGS 84
PERMIT/WAIVER No. IRP
Issued by Water Resources
Parcel No. 006-611-01

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILT		0'	3'	3'
SAND		3'	5'	2'
CLAY		5'	8'	3'
SILT		8'	12'	4'
CLAY		12'	13'	1'
SAND		13'	19'	6'
SILTY SAND		19'	20'	1'
N 39.405052				
W 118.719526 NAD27				

Date started: 10-14-07, 20 07
Date completed: 10-14-07, 20 07

7. Water Level
Static water level: 10' feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

STATE ENGINEERS OFFICE
2007 OCT 30 PM 2:57
RECEIVED

9. WELL CONSTRUCTION
Depth Drilled 20' Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8" Inches		0' Feet	20' Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		SCH. 40	0'	20'

Perforations:
Type of perforation Manufactured Slotted
Size of perforation .010
From 20' feet to 5' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0' to 2' ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 20' to 4' ☐ Pumped ☒ Poured
Type: 2/16 Sand
Bentonite Chips: ☐ Yes ☐ No 4' to 2' ☐ Pumped ☒ Poured
Type: 3/8 Bentonite Chips

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Gregg Drilling (Contractor)
Address 950 Howe Rd (Contractor)
Martinez, CA 94553
Nevada contractor's license number issued by the State Contractor's Board C23-0038113
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2328
Signed (driller performing actual drilling on site or contractor)
Date 10-14-07

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY