WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 104631
Permit No.
Basin 170

NOTICE OF INTENT NO. 30708

1. OWNER ROBERT MAYO
MAILING ADDRESS 1612 COUNCIL BLUFF LANE, LAS VEGAS NV 89031
ADDRESS AT WELL LOCATION 71 COYOTE LANE RACHEL NV 89001

2. LOCATION NE ¼ SE ¼ Sec. 35 T. 3 N (S) R. 55 (E) LINCOLN County
PERMIT NO. Issued by Water Resources | 010-162-06 Parcel No. | SUNRISE ACRES Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL - SILT		0	7	7
RED SAND & GRAVEL		7	27	20
HARD RED GRAVEL		27	31	4
RED SAND & SOME CLAY		31	92	61
BROWN SANDY CLAY		92	105	13
BROWN SAND & GRAVEL	YES	105	114	9
BROWN CLAY		114	117	3
SAND & GRAVEL		117	149	32
GRAVEL & COBBLES		149	185	36

DCNR/DWR RECEIVED DEC 24 2007 LAS VEGAS OFFICE

Date started 30 - SEPT, 2007, 19
Date completed 01 - DEC, 2007, 19

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10	2-3	4
GPS	-WG-84	
	N 37° 38.381'	
	W 115° 45.258'	
ELEVATION	4798	

8. WELL CONSTRUCTION
Depth Drilled 185 Feet Depth Cased 185 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
9 7/8"	0	55
7 7/8"	55	185

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"	PVC	SC 40	+1	185

Perforations:
Type perforation VERTICAL / BLADE
Size perforation 1/8" x 6" x 4 ROWS
From 140 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50.5
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 185 feet to 50.5 feet

9. WATER LEVEL
Static water level 96 feet below land surface
Artesian flow NONE G.P.M. P.S.I.
Water temperature 61 °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RCB3 INC Contractor
Address 6411 W DEER SPRING WAY Contractor
LAS VEGAS NV 89131
Nevada contractor's license number issued by the State Contractor's Board 0020301
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2064
Signed [signature] By driller performing actual drilling on site or contractor
Date 21 - DEC. 2007

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627