

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24605

1. OWNER Galtar LLC
 MAILING ADDRESS 3275 E SARADA AVE LAS VEGAS, NV 89104
 ADDRESS AT WELL LOCATION 5243 W CHARLESTON BLVD LAS VEGAS, NV 89146
 2. LOCATION NW 1/4 NE 1/4 Sec 01 T 21 N 60 E CLARK County
 PERMIT NO. 1630150100 Parcel No. _____ Subdivision Name PT CUV LOT 2

3. WORK PERFORMED
 New Well Replac Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt		0	3"	3"
CLAY SAND GRAVEL		3"	17'	14'
SANDY CLAY		17'	28'	11'
SANDY CLAY / GRAVEL		28'	55'	27'

well #2
 E 715 LOT 45
 N 26759574.605 NAD83

DEC 06 2007

LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 55' Feet Depth Cased 55' Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"				

Perforations:
 Type perforation .020 2" PVC
 Size perforation .020 2" PVC
 From 55' feet to 40' screen feet
 From _____ feet to _____ feet
 From 40' feet to 0' BLANK feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 55' feet to 38' feet

9. WATER LEVEL
 Static water level 37.94 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 18 Oct, 2007
 Date completed 19 Oct, 2007

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Thomas Campbell Contractor
 Address 6380 S POLARIS LAS VEGAS 89118 Contractor
Kleindelder
 Nevada contractor's license number issued by the State Contractor's Board 0030182
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 2323
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 21 Oct 07