REPORT NO. A07.92

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 104649
PERMIT NO.
BASIN Ø84

NOTICE OF INTENT NO. 61148

1. OWNER Roy & Suzanna Johnson
MAILING ADDRESS PO Box 3977, Sparks NV 89432

ADDRESS OF WELL 150 Red Corral Trail
Palomino Valley, NV 89510

2. WELL LOCATION SE 1/4 SW 1/4 SEC. 8 T 21 R 22 E Washoe COUNTY

PERMIT NO ____ PARCEL NO 77-410-13 SUBDIVISION NAME ____

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [X] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Black Rock		0	20	20
Black Rock & Brown Clay		20	40	20
Black Rock		40	60	20
Multicolored Rock		60	120	60
Black Rock		120	130	10
Black Rock & Orange Clay		130	140	10
Black Rock		140	150	10
Black Rock & Brown Clay		150	197	47

RECEIVED 2007 OCT 24 AM 11:08 STATE ENGINEER'S OFFICE

Notes: WGS-84 GPS: Latitude: N3941.760 Longitude: W119 32.514. After lot line adjustment, well will be on Parcel # 77-410.15-305 Red Corral Trail.
N 39.69610
W 119.540899 NAD27

Date Started 10/11/2007 Date Completed 10/18/2007

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	12	50	3

8. WELL CONSTRUCTION
Depth Drilled 197' Depth Cased 197'

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches 0 Feet 50 Feet
8 1/2 Inches 50 Feet 197 Feet
____ Inches ____ Feet ____ Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8"	12.92	.188	+2'	197'

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 x 3
From 117 Feet to 197 Feet
From ____ Feet to ____ Feet
From ____ Feet to ____ Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 50
PLACEMENT METHOD: [ ] Pumped [X] Poured

SEAL TYPE:
[ ] Neat Cement
[ ] Cement Grout
[X] Concrete Grout
[ ] Bentonite

GRAVEL PACKED: [X] Yes [ ] No
From 50 Feet to 197 Feet

9. WATER LEVEL
Static Water Level 130' Feet Below Land Surface
Artesian Flow ____ GPM ____ PSI
Water Temperature Cold F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.

Name Aqua Drilling & Well Service, Inc
Address 675 Edison Way
Reno, NV 89502

NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 1132T

Signed Roger Mitchell
By driller performing actual drilling on site or contractor

Dated Oct 22 2007