

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34805

1. OWNER: Janell 3 Development LLC ADDRESS AT WELL LOCATION: 8200 Lane Mountain Rd, Las Vegas
 MAILING ADDRESS: 8350 W Sahara Ave # 290, Las Vegas NV 89117
 2. LOCATION: S.W. 1/4 S.W. 1/4 Sec. 33 T. 19 N(S) R. 60 E Clark County
 PERMIT NO. 125-33-401-027 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Abandoned existing well to 430'				
Refer well log # 72528				
Pulled well pump equipment completely from the well. Attempted to pull casing.				
Perforated existing casing from 430' to 90' with a mill knife perforator.				
Pumped in 22 yards of neat cement through a tremmie hose from the bottom of the well to the surface completely filling the well.				
GPS 36° 14' 58 N Nad 83 115° 16' 28 W				
PLUGGING OF LOG # <u>72528</u>				

8. WELL CONSTRUCTION
 Depth Drilled 430' Feet Depth Cased _____ Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>				

 Perforations:
 Type perforation mill knife
 Size perforation _____
 From 430' feet to 90' feet
 From _____ feet to _____ feet
 From Cut 4 times feet to _____ feet
 From around every feet to _____ feet
 From 2 feet feet to _____ feet
 Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal _____ Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started 1-4-08
 Date completed 1-17-08

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 14.8 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name TDC Drilling Contractor
 Address 2870 W Pebble Rd Las Vegas, NV 89123 Contractor
 Nevada contractor's license number 59948 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2010
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 1-17-08