STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 104684
Permit No.
Basin 176

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61896

1. OWNER RANDALL I. WRIGHT
MAILING ADDRESS 212 WINTERS DRIVE
CARSON CITY, NV 89703-3730

ADDRESS AT WELL LOCATION 1.6 MILES S. OF END OF ST HWY 229
EAST SIDE OF THE ROAD, RUBY VALLEY, NV
Subdivision Name: County: ELKO

2. LOCATION SE ¼ NE ¼ Sec 10 T 31N N/S R 59 E
PERMIT/WAIVER No. 007-~~029~~-033 (issued by Water Resources) Parcel No.
Latitude 40.563297
Longitude 115.254144
UTM E 11T 0644372 [X] NAD 27
N 4493688 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	2	2
BROWN CLAY		2	6	4
BROWN CLAY & SOME		6	60	54
GRAVEL MIX				
GRAVEL & SOME SAND	80-100	60	120	60

Date started: 29-Oct, 20 07
Date completed: 29-Oct, 20 07

9. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	120	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+1.5	120

Perforations:
Type of perforation MACHINED MILL SLOT
Size of perforation 3/16" X 3", 6 ROW
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 5 to 50 [X] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured
Gravel Pack: [X] Yes [ ] No 50 to 120 [ ] Pumped [X] Poured
Type: 3/8" PEA GRAVEL
Bentonite Chips: [ ] Yes [X] No to [ ] Pumped [ ] Poured
Type:

7. Water Level
Static water level: 35 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR LIFT	45		2

STATE ENGINEERS OFFICE
2007 NOV -5 AM 11:36
RECEIVED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1689
Signed (By driller performing actual drilling on site or contractor)
Date 10/31/2007

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY