

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY

Log No. 104717
 Permit No. _____
 Basin 876

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Corrected
 Please fill in this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59775

1. OWNER Mike Specchio
 MAILING ADDRESS P.o. Box 2275 Fallon, NV 89408
 Fallon, NV 89408

ADDRESS AT WELL LOCATION 45 Hwy 95a
 Fernley, NV 89408

2. LOCATION NE 1/4 NE 1/4 Sec 14 T 20 R 24
 PERMIT NO Parcel No. 020-041-57

Latitude 39.60717 Longitude -119.25093 X WGS 84
 Subdivision Name _____ County Lyon

3. TYPE OF WELL Domestic
 Is this well being plugged because a replacement well was drilled? No
 If yes what is replacement well NOI? _____

Is there an existing well log? No
 If yes, what is NDWR well log #? _____

4. EXISTING WELL CONSTRUCTION
 Depth 109 Feet Depth Cased 109 Feet

7. WELL PLUGGING PROCEDURE
 Was well cleaned out to total depth? Yes
 If well was not cleaned out to total depth, please explain why: _____

EXISTING CASING SCHEDULE

Size O.D. (inches)	Weight/ft (pounds)	Wall Thickness	From (feet)	To (feet)
10	28.00	.250	0	109

Was well contaminated? No
 Was casing pulled? No
 Was casing overdrilled? No

Existing Perforations:

Type perforation _____
 Size perforation _____

From _____ feet to _____ feet

If casing was left in place, please show where additional perforations were made:
 Additional Perforations: _____

Type perforator used: Air Roller
 From 0 To 109 Number of perfs per linear foot 20

5. WATER LEVEL

8. WELL PLUGGING MATERIALS

Static Water Level None feet below land surface
 Artesian Flow G.P.M. _____ P.S.I. _____
 Water temperature ° F Quality _____

From	To	Material	Pumped
109 Feet	50 Feet	Bentonite	Pumped
50 Feet	0 Feet	Neat Cement	Pumped

6. Additional Notes or Comments

Perf well total depth - (Air Perf)
 109 - 50 20% 16 Bags grout
 50 - surface Neat Cement (2 Yds.)
IT was a dry well, therefore, there was no static water level.

Neat Cement Fluid Weight 156 lbs/gal
 Bentonite Grout 20 % Bentonite
 Date Started 7/20/2007
 Date Completed 7/20/2007

*N 39.607276
 W 119.249908 NAD27*

9. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc.
 Contracto _____
 Address 403 McLean Road
 Fallon, NV 89407

Contracto _____
 Nevada contractor's license number 29064
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 2285
 Division of Water Resource, the on-site driller

Signed _____
 By driller performing the actual drilling on site or contract
 Date 7/13/2007

STATE ENGINEERS OFFICE
 STATE ENGINEERS OFFICE
 2007 JUL 30 AM 11:45
 2007 NOV 5 AM 11:45
 RECEIVED

RECEIVED
 OCT 08 2007
 BY: (N)