WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 104728
Permit No.
Basin 101

NOTICE OF INTENT NO. 59397

1. OWNER Brent Greening
MAILING ADDRESS 978 Crook DB Fallon NV
ADDRESS AT WELL LOCATION 978 Crook Fallon NV
978 South Crook Road, Fallon, NV 89406

2. LOCATION SW ¼ SW ¼ Sec. 33 T 19 (N)S R 29 (E) Churchhill County
PERMIT NO. R-543 (Issued by Water Resources) 007-851-10 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other plugged

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	10'	
Sands		10	20	
Gray Clay		20	30	
Black Clay		30	50	
Brown clay		50	65	
Gravel & Sand small Amount of Clay	*	65	80	
Gray Clay		80	220	
Black & gray clay		220	355	
Pumped Bentonite grout from		20 ft	355 ft	
Pumped neat cement from		[illegible] ft	20 ft	
Poured cement grout		[illegible]	[illegible]	
From surface 8 ft				
GPS 39° 27.757 N 118° 44.420 W				

Date started Drilling And plugging First part plugging of 3-29-07
Date completed Last pour of seal 0+08 ft 7-12-07

7. WELL TEST DATA 3-29-07 to 7-12-07

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N 39.462716		
W 118.739358 NAD27		

8. WELL CONSTRUCTION
Depth Drilled 355 Feet Depth Cased 0 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	100 Feet
Inches	Feet	Feet
9 7/8 Inches	100 Feet	355 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
NA	NA	NA	NA	NA

Perforations:
Type perforation NA
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 355
Placement Method: ☒ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level NA feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature NA °F Quality NA

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling (Contractor)
Address BX 599 Silver Springs NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1878
Signed [signature] By driller performing actual drilling on site or contractor
Date 7-12-07

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627