

State 1  
 cust 1

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**



OFFICE USE ONLY  
 Log No. 104729  
 Permit No. \_\_\_\_\_  
 Basin 070

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59630  
5875 PELICAN  
HUMBOLDT  
 County:

1. OWNER Dena Johnson  
 MAILING ADDRESS 40N PATTONSON  
SPARNS NV. 89436  
 2. LOCATION SE 1/4 SE 1/4 Sec 2 T 35 N/S R 37 E  
 PERMIT/WAIVER No. 013-032-38  
Issued by Water Resources Parcel No.

ADDRESS AT WELL LOCATION J. B. Sub.  
 Subdivision Name: \_\_\_\_\_  
 Latitude \_\_\_\_\_ UTM E 434495  NAD 27  
 Longitude \_\_\_\_\_ N 4531374  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	5	5
SANDY CLAY		5	20	15
TAN SANDY CLAY		20	60	40
SAND + GRAVEL		60	80	20
Rocky clay		80	100	20
SANDY CLAY		100	120	20
SAND + GRAVEL		120	140	20
SANDY CLAY		140	150	10

N40.932774  
W117.778066 NAD27

9. WELL CONSTRUCTION  
 Depth Drilled 150 Feet Depth Cased 150 Feet  
 HOLE DIAMETER (BIT SIZE)  
10 5/8 Inches From 0 Feet To 150 Feet  
 \_\_\_\_\_ Inches Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>1.22</u>	<u>71</u>	<u>150</u>

Perforations:  
 Type of perforation Sawed  
 Size of perforation 3/16 x 3  
 From 120 feet to 150 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No  
 Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout 5 to 60  Pumped  Poured  
 Concrete Grout to \_\_\_\_\_  Pumped  Poured  
 80% Bentonite Grout to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 100 to 120  Pumped  Poured  
 Type: \_\_\_\_\_  
 Bentonite Chips:  Yes  No 60 to 100  Pumped  Poured  
 Type: \_\_\_\_\_

7. Water Level  
 Static water level: 47 feet below land surface  
 Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water Temperature: \_\_\_\_\_ °F  
 Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	<u>907</u>	<u>DNK</u>	<u>2 hrs</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name L.B.D. Driller Co.  
 Address P.O. Box 902  
Wmea NV 89446  
 Nevada contractor's license number 9605  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1809  
 Signed \_\_\_\_\_  
 Date 7-8-07