WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 104742
Permit No.
Basin 020

NOTICE OF INTENT NO. 30964

1. OWNER Flying J Inc.
MAILING ADDRESS 333 W. Center St. North Salt Lake, Utah 84054
ADDRESS AT WELL LOCATION 1880 W. Winnemucca Blvd, Winnemucca, NV. Well #1

2. LOCATION SE ¼ SW ¼ Sec. 30 T. 36 N/S R. 38 E. Humboldt County
PERMIT NO. — (Issued by Water Resources) 015-292-08 (Parcel No.) GPS 40°57'37.47" N 117°44'51.65" W (WGS 84) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
FILL 2" Asphaltic Concrete		0	2"	2"
TANK Back Fill		2"	14'	13'10"
Sand		14	25	11
	Wet	16	25	9

N 40.960520
W 117.746712 NAD27

2007 JUL -2 PM 1:13

Date started 6-5, 2007
Date completed 6-5, 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	NA.	

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 22 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	25 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	Sch. 40	PVC F-480	0	22

Perforations:
Type perforation Factory Slots
Size perforation .020
From 7 feet to 22 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 5
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout ☒ Bentonite
Gravel Packed: ☒ Yes ☐ No
From 5 feet to 22 feet

9. WATER LEVEL
Static water level 15.8 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cool °F Quality Poor

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Elite Drilling Inc. (Contractor)
Address 4255 W. Post Rd. (Contractor)
Las Vegas, NV. 89118
Nevada contractor's license number issued by the State Contractor's Board 0054931
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1944
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 6-25-07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627