STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 104755
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31036

1. OWNER Secor International
MAILING ADDRESS 5755 S. Sandhill Rd Suite A
Las Vegas, NV 89120

ADDRESS AT WELL LOCATION 600 N.Las Vegas Blvd
(2 Wells) Las Vegas, NV
Subdivision Name: County: Clark

2. LOCATION SE ¼ SE ¼ Sec 27 T 20 N/S R 61 E
PERMIT/WAIVER No. 139-278-05-002
Issued by Water Resources 139-27-805-002 Parcel No.

Latitude 36 10' 29.25"N
Longitude 115 08 13.23"W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other (AUGER)

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy w/interbeded Caliche		0	14	14
Sandy Silt w/Caliche		14	21	7
Poorly Graded Sand	19	21	30	9

Date started: 26-Apr, 20 07
Date completed: 26-Apr., 20 07

9. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8.5	Inches	0	Feet	30	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5"		Sch 40 PVC	0	15

Perforations:
Type of perforation Factory Slotted
Size of perforation 0.02
From 15 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 0 to 10 ☐ Pumped ☒ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 13 to 30 ☐ Pumped ☒ Poured
Type: #3 Monterey Sand
Bentonite Chips: ☒ Yes ☐ No 10 to 13 ☐ Pumped ☒ Poured
Type: 3/8 Medium Chips

7. Water Level
Static water level: 19 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells
Contractor
Address 570 Corinthian Way
Contractor
Las Vegas, NV 89030
Nevada contractor's license number issued by the *State Contractor's Board* 0012852
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2057
Signed
By driller performing actual drilling on site or contractor
Date 5/1/2007

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY