STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 104762
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34986

1. OWNER Resort Holdings 3 LLC
MAILING ADDRESS 2801 N Tenaya Way
Las Vegas, NV 89128

ADDRESS AT WELL LOCATION Well #1
6235 S. Pecos Rd
Subdivision Name: County: Clark

2. LOCATION NE ¼ SE ¼ Sec 36 T 21 N/S R 61 E
PERMIT/WAIVER No. 162-36-711-004
Issued by Water Resources Parcel No.

Latitude 36 04' 36.77"N
Longitude 115 06' 03.28"W
UTM E 115 6.048
N 36 4.636
[x] NAD 27
[ ] NAD 83/WGS 84

3. WORKED PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [x] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [x] Other (AUGER)

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	3	3
Fill Material w/Gravel		3	5	2
Light Tan Silt and Very Fine Sand		5	10	5
w/Pebbles				
V Light Tan Silty Clay (Moist)		10	15	5
Dark Tan Clay w/Gravel	19	15	25	
Light Tan Clay		25	30	5

Date started: 16-Jan, 20 08
Date completed: 16-Jan, 20 08

9. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8"	Inches	0	Feet	30	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		Sch 40 PVC	0	30

Perforations:
Type of perforation Facotry Slotted
Size of perforation 0.02
From 15 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [x] Yes [ ] No
[ ] Neat Cement to [ ] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[x] ≥30% Bentonite Grout 0 to 13 [ ] Pumped [x] Poured
Gravel Pack: [x] Yes [ ] No 13 to 30 [ ] Pumped [ ] Poured
Type: #3 Monterey Sand
Bentonite Chips: [x] Yes [ ] No 0 to 13 [ ] Pumped [x] Poured
Type: 3/8 Medium Chips

7. Water Level
Static water level: 19 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: [x] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	0	.5

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells
Contractor
Address 570 Corinthian Way
Contractor
Las Vegas, NV 89030
Nevada contractor's license number issued by the *State Contractor's Board* 0012852
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2057
Signed
By driller performing actual drilling on site or contractor
Date 1-31-08

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY