

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 104783

Permit No. \_\_\_\_\_  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **53729**

1. OWNER **Michelle Parrott**  
 MAILING ADDRESS **3549 Mont Blanc Ct.**  
**Carson City, NV 89705**

ADDRESS AT WELL LOCATION **3549 Mont Blanc Ct.**  
**Carson City, NV 89705**

2. LOCATION **SE 1/4 NW 1/4 Sec. 11 T N14** N/S R **E19 E** **Douglas** County  
 PERMIT NO. **141911001008** Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
D.G & Sand		0	10	10
Granite		10	170	160
Broken Granite		170	180	10
Granite		180	250	70
Broken Granite		250	297	47
GPS 39.09488 N. 119.81933 W. <i>NAD83</i>				
T.D. 297 ft				
<i>N39.094982</i>				
<i>W 119.818330 NAD27</i>				

8. WELL CONSTRUCTION  
 Depth Drilled **297** Feet Depth Cased **297** Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<b>11</b>	<b>0</b>	<b>50</b>		
<b>8 3/4</b>	<b>50</b>	<b>297</b>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>6 5/8</b>	<b>12.9</b>	<b>.188</b>	<b>0</b>	<b>297</b>

Perforations:  
 Type perforation **Factory**  
 Size perforation **3/32 x 3**

From	To	Feet	Feet
	<b>297</b>		<b>237</b>
	<b>177</b>		<b>147</b>

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal **50**

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From **297** feet to **50** feet

9. WATER LEVEL  
 Static water level **160** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature **Cold** °F Quality **Good**

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **A.S.A.P. Pump & Well Service LLC** Contractor  
 Address **P.O. Box 60130** Contractor  
**Reno, NV 89506**  
 Nevada contractor's license number issued by the State Contractor's Board **35387C**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1509/2187**  
 Signed *[Signature]*  
 By driller performing actual drilling on-site or contractor  
 Date **11/1/2007**

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<b>30</b>	<b>297</b>	<b>2 HRS</b>
<b>20</b>	<b>111</b>	<b>8 - 10 HRS</b>