STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 104809
Permit No.
Basin 049

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59687

1. OWNER STEPHEN CURRY
MAILING ADDRESS 290 BULLION ROAD
ELKO, NV 89801

ADDRESS AT WELL LOCATION 1914 JAMIE LANE
ELKO, NV
Subdivision Name: PARCEL OF LAND County: ELKO

2. LOCATION SW ¼ ~~SW~~ NW ¼ Sec 17 T 34N N/S R 55 E
PERMIT/WAIVER No. 006-09F-082
Issued by Water Resources Parcel No.

Latitude 40.835149
Longitude 115.811785
UTM E 11T 0600183 ☒ NAD 27
N 4520925 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	2	2
SAND & GRAVEL		2	6	4
CEMENTED & GRAVEL		6	55	49
SILTSTONE & GRAVEL		55	200	145
GRAVEL & SOME SILTSTONE	300	200	340	140

Date started: 31-May , 20 07
Date completed: 4-Jun , 20 07

9. WELL CONSTRUCTION
Depth Drilled 340 Feet Depth Cased 340 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	340	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13.0	.188	+1	340

Perforations:
Type of perforation MACHINE MILL SLOT
Size of perforation 3/16" X 3"
From 320 feet to 340 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 5 to 50 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 55 to 340 ☐ Pumped ☒ Poured
Type: 3/8" PEA GRAVEL
Bentonite Chips: ☒ Yes ☐ No 50 to 55 ☐ Pumped ☒ Poured
Type: 3/8" BENTONITE CHIPS

7. Water Level
Static water level: 252 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		6

2007 JUN 25 AM 9:30

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1689
Signed (By driller performing actual drilling on site or contractor)
Date JUNE 4, 2007

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY