

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34807

1. OWNER COUNTY OF CLARK (PARK & COMM SERV) ADDRESS AT WELL LOCATION 1020 BROADBENT BLVD
 MAILING ADDRESS 5525 South Valley View #10 WHITNEY LIST STATION LAS VEGAS NV.
LAS VEGAS NV 89118

2. LOCATION NW 1/4 SE 1/4 Sec 26 T 21 N R 62 E County CLARK
 PERMIT NO. DW-1237 Issued by Water Resources Parcel No. 161-26-701-001 Subdivision Name CLARK

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. Dewater PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>4" Well Abandonment</u>		<u>GRADE</u>		<u>49'</u>
<u>14" CASING</u>		<u>49'</u>	<u>49'</u>	
<u>CLAY-TAN</u>		<u>49'</u>	<u>51'</u>	<u>2'</u>
<u>STEEL-DRATE</u>				
<u>mill knife-perforation</u>				
<u>4 PASSED</u>				
<u>Waiver # DW-1237</u>				
<u>GPS 36° 05' 29" N NAD 83</u>				
<u>115° 01' 07" W</u>				
<u>8 yard-Neatcement</u>				
<u>ATT: PULLED CASING</u>				

8. WELL CONSTRUCTION
 Depth Drilled 51' Feet Depth Cased 49' Feet

HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To GRADE Feet
51' Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>1</u>				
<u>14"</u>	<u>BLANK</u>	<u>.250</u>	<u>GRADE</u>	<u>30'</u>

Perforations:
 Type perforation FACTORY
 Size perforation 1/4 x 2.5" LONG 16 AROUND
 From 30' feet to 50' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal NONE Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started FEB 18 2008, 20 _____
 Date completed FEB 18 2008, 20 _____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

FEB 20 2008
LAS VEGAS OFFICE

9. WATER LEVEL
 Static water level 7' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name T.D.C. Drilling Water Well & Pump Service
 Address 2870 W PEBBLE RD
LAS VEGAS NV 89123
 Nevada contractor's license number 5994.8
 issued by the State Contractor's Board
 Nevada driller's license number issued by the #2010
 Division of Water Resources, the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date FEB 20 2008