

PXW-7

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 104905  
Permit No.  
Basin 212

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34880

1. OWNER County of Clark (PK & Connie Saw)  
MAILING ADDRESS 3770 Howard Hughes Parkway #200

ADDRESS AT WELL LOCATION 6800 E Russell Rd.

Subdivision Name: County: Clark

2. LOCATION SW 1/4 SW 1/4 Sec 25 T 21 N 62 E  
PERMIT/WAIVER No. MO-2793 161-25-401-001  
Issued by Water Resources Parcel No.

Latitude UTM E 826450 NAD 27  
Longitude N 26733450 NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  Stock  
 Municipal/Industrial  Monitor

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Roto Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Silty Sand		0	7	7'
Sandy Gravel		7	17	10'
Caliche	X	17	48	31'
Muddy Creek	X	48	54	6'

9. WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	Feet
54		50'	

HOLE DIAMETER (BIT SIZE)

	From	To	Feet	Feet
8 Inches	0	50'		
6 Inches	50	54		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	7	.237	0	25

Perforations:  
Type of perforation Factory Slot  
Size of perforation 1.040  
From 25 feet to 50 feet  
From feet to feet  
From feet to feet  
From feet to feet

Annular Seal:  Yes  No  
 Neat Cement to  Pumped  Poured  
 Cement Grout to  Pumped  Poured  
 Concrete Grout 0 to 2  Pumped  Poured  
 ≥30% Bentonite Grout 2 to 18  Pumped  Poured  
Gravel Pack:  Yes  No 24 to 51  Pumped  Poured  
Type: 6-9- silica sand  
Bentonite Chips:  Yes  No 51 to 57  Pumped  Poured  
Type: 3/8 Hulephg 18 24

Date started: 12-14 20 07  
Date completed: 12-17 20 07

7. Water Level  
Static water level: 17 feet below land surface  
Artesian Flow: G.P.M. P.S.I.  
Water Temperature: °F  
Quality:

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name: Boart Longyear Co  
Address: 7773 W Seldon In Peoria, AZ 85345

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

Nevada contractor's license number issued by the State Contractor's Board 0010157  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2147  
Signed: [Signature]  
By driller performing actual drilling on site or contractor  
Date: 1-6-08