

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 104915
 Permit No. _____
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33252

1. OWNER T-WHR LLC ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1 MAIN ST 900 S. FREMONT ST.
LAS VEGAS NV LAS VEGAS NV
 2. LOCATION SE 1/4 NE 1/4 Sec 39 T. 20 N/S R. 61 E CLARK County
 PERMIT NO. 139-34-612-059 Parcel No. _____ Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT		0	10"	10"
TYPE II		10"	2.5'	1'3"
SILTY CLAY		2.5'	6'	3.5'
CRACKL		6'	10'	4'
CLAYE SILT		10'	21'	11'
CLAY		21'	23'	2'
WEAK CRACKL		23'	26'	3'
SILTY CLAY		26'	40'	14'
AS 1.5" OD X 18.0 L SPARGE POINT ARM				
37.5' 1.0" 10 SC480 PVC				
AS2: 1.5" OD X 18.0 L SPARGE POINT ARM				
87.5' 1.0" 10 SC480 PVC				
V61: 4.25" OD SC4 40 PVC, 200 SCREEN (10')				
4.25" OD SC4 40 PVC CASING (5')				
MAP DATUM <u>WGS 84</u>				
<u>36° 10' 10" N 115° 08' 06" W</u>				
FACILITY <u>10#</u>				
<u>8-600377</u>				

8. WELL CONSTRUCTION
 Depth Drilled 40 Feet Depth Cased 39 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
11 1/2 Inches 0 Feet 40 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.25</u>		<u>SC4 80 PVC</u>	<u>39</u>	<u>0</u>
<u>1.0"</u>		<u>SC4 80 PVC</u>	<u>29</u>	<u>0</u>
<u>1.0"</u>		<u>SC4 40 PVC</u>	<u>15</u>	<u>0</u>

Perforations:
 Type perforation MACHINE SECT
 Size perforation 1.028
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From 1.5 feet to 5 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 3 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 40/30/15.5 feet to 35/25/3 feet

9. WATER LEVEL
 Static water level 17 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EAGLE DRILLING SERVICES LLC Contractor
 Address 7150 PLAIN ST. Contractor
LAS VEGAS NV. 89119
 Nevada contractor's license number 51266
 issued by the State Contractor's Board
 Nevada driller's license number issued by the M-2272
 Division of Water Resources, the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 2/29/8

Date started 2/22, 2008.
 Date completed 2/22, 2008.

7. WELL TEST DATA
 TEST METHOD: Bailor Pump Air Lift

G.P.M.	Drawdown (Feet)	Time (Hours)

RECEIVED
 MAR 05 2008
LAS VEGAS OFFICE