

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 104935
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32662

1. OWNER SH LLC
 MAILING ADDRESS 981 W HICKORY ST.
PAHRUMP, NV

ADDRESS AT WELL LOCATION 981 W HICKORY ST.

2. LOCATION SW 1/4 SW 1/4 Sec. 28 T 20S
 PERMIT NO. 40-391-07
Issued by Water Resources Parcel No.

N/S R 53E E NYE County
CALVADA VALLEY UNIT 5
Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY & CALICHE	0	74		
CALICHE	WB	74	76	2
CLAY		76	94	18
CALICHE	WB	94	97	3
CLAY		97	112	15
CALICHE	WB	112	116	4
CLAY		116	131	15
CALICHE	WB	131	133	2
CLAY		133	154	21
CALICHE	WB	154	156	2
CLAY		156	177	21
CALICHE	WB	177	181	4
CLAY		181	200	19

WGS84
 N 36 DEGREES 10.655
 W 116 DEGREES 01.899

DONOR
 RECEIVED
 FEB 11 2008

LAS VEGAS OFFICE

Date started 2/6/2008 19
 Date completed 2/7/2008 19

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			

8. WELL CONSTRUCTION

Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>10</u>	<u>0</u>	<u>200</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>3.63</u>	<u>.280</u>	<u>0</u>	<u>200</u>

Perforations:

Type perforation SAWCUT
 Size perforation 1/8 X 3

From <u>100</u> feet to	<u>120</u> feet
From <u>140</u> feet to	<u>160</u> feet
From <u>180</u> feet to	<u>200</u> feet
From _____ feet to	_____ feet
From _____ feet to	_____ feet

Surface Seal: Yes No
 Depth of Seal 50
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL

Static water level 53 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC.
Contractor

Address 1220 E MANSE RD
Contractor

PAHRUMP, NV. 89048

Nevada contractor's license number issued by the State Contractor's Board 47333

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642

Signed [Signature]
 By Driller performing actual drilling on-site or contractor

Date 2/7/2008