

**STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT**

OFFICE USE ONLY
Log No. 104947
Permit No. _____
Basin 212

**PRINT OR TYPE ONLY
DO NOT WRITE ON BACK**

Please complete this form in its entirety in accordance with NRS 534.171 and NAC 534.040

NOTICE OF INTENT NO. 34696

1 OWNER ATTORNEY AT LAW ADDRESS AT WELL LOCATION NEAR NW CORNER
MAILING ADDRESS 2620 REGATTA DR. ON TIARA WAY + HICKAM AVE
LAS VEGAS, NEV 89128 Subdivision Name _____ County CLARK

2 LOCATION NW 1/4 S.W. 1/4 Sec 23 T 20S R 60E E Latitude N 36° 14' 15.3" UTM E _____ NAD 27
PERMIT/WAIVER NO R-1401 138-03-394.016 Longitude W 115° 15' 32.9" N _____ NAD 83/WGS 84

3 TYPE OF WELL Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

Is this well being plugged because a replacement well was drilled? no Is there an existing well log? no
If yes, what is replacement well NO#? _____ If yes, what is NDWR well log #? _____

4 EXISTING WELL CONSTRUCTION

Depth Drilled ? Feet Depth Cased 200 Feet

EXISTING CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Well Thickness (Inches)	From (Feet)	To (Feet)
<u>2 3/8</u>	<u>17.3</u>	<u>1.55</u>	<u>0</u>	<u>200</u>

7 WELL PLUGGING PROCEDURE

Was well cleaned out to total depth? yes no

If well was not cleaned out to total depth, please explain why: could not get tools past 200'

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no

If casing was left in place, please show where additional perforations were made:

Existing Perforations:

Type of perforation	Size of perforation	From	feet to	feet

Additional Perforations:

Type of perforator used: Air Perforator

From	feet to	feet	Number of perfs per linear foot
<u>50</u>	<u>200</u>		<u>32</u>

5 WATER LEVEL

Static water level 85.5 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

8 WELL PLUGGING MATERIALS

From	feet to	feet	Material Used	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<u>200'</u>	<u>5'</u>		<u>Neat Cement</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>

6 Additional Notes or Comments

Tried to clean out to bottom. Ran into obstruction at 200', could not get bit past. Applied for waiver from Division # R-1401. as per waiver perfoled from 200' to 50'.

Neat Cement Fluid Weight _____ lbs/gal
Bentonite Grout _____ % bentonite

Date Started 2-13-08
Date Completed 2-15-08

9 DRILLER'S CERTIFICATION

This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.

Name Redding Drilling & Pump Svc Contractor
Address 530 E Larsen Ln Contractor
Henderson, NV 89044

Nevada contractor's license number issued by the State Contractor's Board 38155
Nevada driller's license number issued by the Division of Water Resources, the co-size driller 2063

Signed Ken Torshy By driller performing actual drilling on site or contractor
Date 2-15-08

RECEIVED
FEB 19 2008
LAS VEGAS OFFICE

USE ADDITIONAL SHEETS IF NECESSARY