



Log No. 104967
 Permit No. 72353T/7A128
 Basin 031-DESERT V1

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 55645

1. OWNER CRAWFORD FARMS ADDRESS AT WELL LOCATION 2.5 miles North Jungo Road N40 58 23 93"
 MAILING ADDRESS 5195 E Kierkway Drive 22 miles west of Winn NV 118 10 43 25"
Winn, NV 89445
 2. LOCATION SW 1/4 SW 1/4 Sec. 21 T 36 N 34 E Humboldt County
 PERMIT NO. 72353-T Parcel No. NA Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	3	3
SAND Fine Gravel		3	25	22
COURSE SAND Gravel		25	48	23
CLAY SAND Gravel		48	90	42
COURSE SAND Gravel	XX	90	150	60
COURSE SAND	XX	150	250	100
SAND + Gravel	XX	250	280	30
COURSE SAND	XX	280	310	30
SAND + Gravel	XX	310	350	40
SAND	XX	350	360	10

2007 MAR -1 10:56
 STATE ENGINEER'S OFFICE

N 40.973429
W 118.177699 NAD27

8. WELL CONSTRUCTION
 Depth Drilled 360 Feet Depth Cased 353 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
30" Inches 0 Feet 50' Feet
24" Inches 50 Feet 360 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>24"</u>		<u>.250</u>	<u>+2</u>	<u>50'</u>
<u>16"</u>		<u>.250</u>	<u>+2</u>	<u>353'</u>

Perforations:
 Type perforation FACTORY SAW CUT
 Size perforation .125 32 Row + 64 Row
 From 93 feet to 213 32R feet OPEN AREA 1967
 From _____ feet to _____ feet OPEN AREA
 From 213 feet to 353 64R feet 39.34
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 0 feet to 353' feet

9. WATER LEVEL
 Static water level 43 feet below land surface
 Artesian flow NO G.P.M. _____ P.S.I. _____
 Water temperature GOOD °F Quality COOL

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name FRED ANDERSON Contractor
 Address 10760 GRASS VALLEY ROAD Contractor
Winn NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 021467
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1375
 Signed _____
 By driller performing actual drilling on site or contractor
 Date Aug 16 05

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>1460</u>	<u>43/90</u>	<u>8 hours</u>