


STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 104968
Permit No. _____
Basin 212



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61770

1. OWNER US Nellis AFB
MAILING ADDRESS Washington DC 20025-0000

ADDRESS AT WELL LOCATION Sta LF-01
Nellis AFB, Nevada

2. LOCATION SW 1/4 SE 1/4 Sec 16 T 20 N R 62 E
PERMIT/WAIVER No. 170-16-801-001

Subdivision Name: _____ County: Clark
Latitude _____ Longitude _____
UTM E 812,667 NAD 27
N 26,776,302 NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other Abandonment

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Rate Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Tremie Grout</u>				
<u>from 233' to 0' to</u>				
<u>1 ft water out of hole</u>				
<u>Pull Surface Pipe</u>				
<u>out of hole 3' below</u>				
<u>grade Break off PVC</u>				
<u>2' below</u>				
<u>80 Gallons of Portland</u>				

9. WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	Feet	
HOLE DIAMETER (BIT SIZE)				
	From	To		
	Inches	Feet	Feet	
	Inches	Feet	Feet	
	Inches	Feet	Feet	
CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:

Type of perforation _____
Size of perforation _____

From _____ feet to _____ feet
From _____ feet to _____ feet

Annular Seal: Yes No

Neat Cement to _____ Pumped Poured
 Cement Grout to 0 to 233 Pumped Poured
 Concrete Grout to _____ Pumped Poured
 230% Bentonite Grout to _____ Pumped Poured

Gravel Pack: Yes No to _____ Pumped Poured

Type: _____
Bentonite Chips: Yes No to _____ Pumped Poured
Type: _____

Date started: 2-5- 20 08
Date completed: 2-5- 20 08

7. Water Level
Static water level: 50' feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: _____ °F
Quality: _____

8. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Time (hours)
DCNR/DWR RECEIVED	
MAR 12 2008	
LAS VEGAS OFFICE	

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Boart Longyear Co Contractor
Address 7773 W Seldon Ln Contractor
Peoria Az. 85345
Nevada contractor's license number 0010157
issued by the State Contractor's Board
Nevada driller's license number issued by the M-2147
Division of Water Resources, the on-site driller
Signed Shu Li
By driller performing actual drilling on site or contractor
Date 2-22-08