



WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33263

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER Clark County ADDRESS AT WELL LOCATION No. ADDRESS
 MAILING ADDRESS 500 S. GRAND CENTRAL BLVD
LAS VEGAS NV
 2. LOCATION SW 1/4 SW 1/4 Sec 10 T. 21 N/S R. 61 E CLARK County
 PERMIT NO. 16270-499008 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other NSR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>ASPHALT</u>		<u>0</u>	<u>.4</u>	<u>.4</u>
<u>TYPE II</u>		<u>.4</u>	<u>1.5</u>	<u>1.1</u>
<u>Silty Sand</u>		<u>1.5</u>	<u>4.5</u>	<u>3.0</u>
<u>Gravel</u>		<u>4.5</u>	<u>8</u>	<u>3.5</u>
<u>Silty Clay</u>		<u>8</u>	<u>12</u>	<u>4</u>
<u>Silty Clay w/Gravel</u>		<u>12</u>	<u>17</u>	<u>5</u>
<u>Clay</u>		<u>17</u>	<u>24</u>	<u>7</u>
<u>Clay w/Gravel</u>		<u>24</u>	<u>31</u>	<u>7</u>

MAP DATUM
 WGS 84
 36°07.918N 115°09.298W

Facility 10 #
 8-000814

Date started 3/21, 2008
 Date completed 3/22, 2008

7. WELL TEST DATA

TEST METHOD	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>G.E.M.</u>	
	<u>MAR 27 2008</u>	
	<u>LAS VEGAS OFFICE</u>	

8. WELL CONSTRUCTION
 Depth Drilled 31 Feet Depth Cased 30 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 31
8 1/2 Inches 0 Feet 31 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.0</u>		<u>5/8 40 PVC</u>	<u>30</u>	<u>0</u>

Perforations:
 Type perforation MACHINE SLOT
 Size perforation .020
 From 30 feet to 15 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 13' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 31 feet to 13 feet

9. WATER LEVEL
 Static water level 22 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ETABLE DRILLING SERVICES LLC Contractor
 Address 7150 PLANO ST. Contractor
LAS VEGAS NV 89119
 Nevada contractor's license number issued by the State Contractor's Board 57266
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2272
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 3/24/08