WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 105071
Permit No.
Basin 105

NOTICE OF INTENT NO. 60198

1. OWNER Douglas County
MAILING ADDRESS
ADDRESS AT WELL LOCATION Douglas Co. Effluent Storage Res. NV.

2. LOCATION ~~NE~~ SE ¼ ~~NE~~ SE ¼ Sec. ~~29~~ 20 T. 14 N/S R. 20 E/W Douglas County
PERMIT NO. Nevle0025 (Issued by Water Resources) 1420-29-001-003 (Parcel No.) 119° 45.39w 39° 03.37N (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other auger

6. LITHOLOGIC LOG abandon well #3

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| well was in good condition. with drill rods, knocked out bottom cap and pumped neat cement from bottom to top. | 13' | | | |
| N39.056245 | | | | |
| W 119.755044 NAD27 | | | | |

Date started 12/12, 2007
Date completed 12/12, 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| N/A | | |

8. WELL CONSTRUCTION
Depth Drilled 22 Feet Depth Cased 22 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| Inches | Feet | Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2 | PVC | sch 40 | 0 | 22 |

Perforations:
Type perforation 020
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 22'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 13 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature cold °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Andresen Drilling (Contractor)
Address 1435 Bedford rd. Reno, NV 89509 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed (By driller performing actual drilling on site or contractor)
Date 12/28/07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627