STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 105072
Permit No.
Basin 071

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59640 ~~59643~~

1. OWNER Noel Cebellos
MAILING ADDRESS 9305 Betty Ln
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION 9305 Betty Ln
Winnemucca, Nv 89445
Subdivision Name: County: Humboldt

2. LOCATION SW ¼ ~~SE~~ ¼ Sec 30 T 35N N/S R 38 E
PERMIT/WAIVER No. NW 010-532-09
Issued by Water Resources Parcel No.

Latitude 40.882705
Longitude 117.752305
UTM E 436616 N 4525797
[x] NAD 27 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[ ] New Well [x] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[x] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [x] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	25	25
Gravel and Sand		25	45	20
Gravel and Clay		45	165	120
Gravel and Sand		165	185	20
Gravel and Clay		185	225	20
Cobbles and Clay		225	245	20
Gravel and Clay		245	300	55

Date started: 1-Dec, 20 07
Date completed: 5-Dec, 20 07

9. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	300	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625		0.188	+2	300

Perforations:
Type of perforation wheel perforator
Size of perforation 3/16 x 1 1/4
From 240 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [x] Yes [ ] No
[ ] Neat Cement to [ ] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[x] Concrete Grout 5 to 52 [ ] Pumped [x] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured
Gravel Pack: [x] Yes [ ] No 52 to ~~260~~ 300 [ ] Pumped [x] Poured
Type: 3/8 minus
Bentonite Chips: [ ] Yes [ ] No to [ ] Pumped [ ] Poured
Type:

7. Water Level
Static water level: 172 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool °F
Quality: good

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [x] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35		2

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name American Drilling & Pump Service (Contractor)
Address 3040 Callahan St (Contractor)
Winnemucca, NV 89445
Nevada contractor's license number issued by the *State Contractor's Board* 0020578
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2208
Signed (Driller performing actual drilling on site or contractor)
Date 1-14-08

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY