

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



OFFICE USE ONLY
Log No. 105073
Permit No. _____
Basin 671

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59643

1. OWNER James Mckillop ADDRESS AT WELL LOCATION 9905 Sabin Dr.
MAILING ADDRESS 6225 Bonanza Dr. Winnemucca, Nv 89445
Winnemucca, NV 89445 Subdivision Name: Tycana County: Humboldt

2. LOCATION SW ¼ SE ¼ Sec 30 T 35N N/S/R 38 E Latitude 40.874467 UTM E 437372 NAD 27
PERMIT/WAIVER No. 010-843-18 Longitude 117.743240 N 4524876 NAD 83/WGS 84

Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand and Cobbles		0	25	25
Cemented Gravel and Sand		25	85	60
Gravel and Clay		85	105	20
Cemented		105	125	20
Gravel		125	165	40
Gravel and Clay	X	165	265	100
			260	95

9. WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	Feet
260		260	

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
10 5/8	0	260	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625		0.188	+2	260

Perforations:

Type of perforation wheel perforator
Size of perforation 3/16 x 1 1/4

From 220 feet to 260 feet
From _____ feet to _____ feet

Annular Seal: Yes No

Neat Cement to _____ Pumped Poured
 Cement Grout to _____ Pumped Poured
 Concrete Grout 5 to 52 Pumped Poured
 ≥30% Bentonite Grout to _____ Pumped Poured

Gravel Pack: Yes No 52 to 260 Pumped Poured
Type: 3/8 minus
Bentonite Chips: Yes No to _____ Pumped Poured
Type: _____

7. Water Level
Static water level: 189 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: cool °F
Quality: good

8. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
18		2

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name American Drilling & Pump Service
Contractor
Address 3040 Callahan St
Contractor
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 0020578
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2208

Signed [Signature]
By driller performing actual drilling on site or contractor
Date 1-14-08