STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 105123
Permit No.
Basin 066

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61266

1. OWNER Barrick Gold Exploration
MAILING ADDRESS 293 Spruce Road
Elko, NV 89801

ADDRESS AT WELL LOCATION 19 mi. NE of Golconda
Hole #RMW2SE
Subdivision Name: County: Humboldt

2. LOCATION NW ¼ SW ¼ Sec 34 T 38N N/S R 42 E
PERMIT/WAIVER No. NEV2005102
Issued by Water Resources Parcel No.

Latitude 41.127150 Longitude 117.237067
UTM E 480098.43 N 4552687.04 [x] NAD 27 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [x] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [x] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium & Clay		0	200	200

Date started: 11-Dec, 20 07
Date completed: 13-Dec, 20 07

9. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 198 ~~200~~ Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
14	Inches	0	Feet	20	Feet
8 3/4	Inches	20	Feet	200	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	Nominal	Sch. 80	+2	198

Perforations:
Type of perforation Slotted
Size of perforation 0.02
From 158 feet to 198 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [x] Yes [ ] No
[x] Neat Cement 0 to 50 [ ] Pumped [x] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [x] Yes [ ] No 155 to 200 [ ] Pumped [x] Poured
Type: #8 Sand
Bentonite Chips: [x] Yes [ ] No 50 to 155 [ ] Pumped [x] Poured
Type: 3/8" kwik plug

7. Water Level
Static water level: 149 feet below land surface
Artesian Flow: No G.P.M. N/A P.S.I.
Water Temperature: Cool °F
Quality: Milky

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [x] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
8	51	30 min

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Company, Inc. (Contractor)
Address PO Box 2748 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 0030823
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-2260
Signed Reese Schorel by (MW) (By driller performing actual drilling on site or contractor)
Date 12/13/2007

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY