STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 10536
Permit No.
Basin 071

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

*Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 60213

1. OWNER Dillon Ham
MAILING ADDRESS 3070 Cougar Crt Wmca Nv 89445
SE

ADDRESS AT WELL LOCATION Germain dr. 6460 Germain
Winnemucca, NV 89445
Subdivision Name: County: Humboldt

2. LOCATION ~~NE~~ ¼ NE ¼ Sec 12 T 35N N/S R 37 E
PERMIT/WAIVER No. 013-475-05
*Issued by Water Resources* Parcel No.

Latitude 40.925395
Longitude 117.755212
UTM E ~~436414~~ [x] NAD 27 436412E
N ~~4535~~34 [ ] NAD 83/WGS 84
4530538

3. WORKED PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[x] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [x] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand & gravel | x | 0 | 160 | 160 |

Date started: 20-Jul, 20 07
Date completed: 22-Jul, 20 07

9. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 10 5/8 | Inches | 0 | Feet | 160 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6.625 | | .188 | +2 | 160 |
| | | | | |
| | | | | |

Perforations:
Type of perforation punched
Size of perforation 3/16 x1
From 120 feet to 155 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [x] Yes [ ] No
[ ] Neat Cement to [ ] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[x] Concrete Grout 5 to 54 [ ] Pumped [x] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured
Gravel Pack: [x] Yes [ ] No 54 to 160 [ ] Pumped [x] Poured
Type:
Bentonite Chips: [ ] Yes [ ] No to [ ] Pumped [ ] Poured
Type:

7. Water Level
*Static water level:* 97 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool °F
Quality: good

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [x] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20 | | 1 |

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name American Drilling & Pump Service
Contractor
Address 3040 Callahan St
Contractor
Winnemucca, NV 89445
Nevada contractor's license number issued by the *State Contractor's Board* 0020578
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2208
Signed Owen Brinkerhoff
By driller performing actual drilling on site for contractor
Date 8-9-07

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY