

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. **105144**
 Permit No. _____
 Basin **162**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **31142**

1. OWNER **Dean & Jeneese Valencia**
 MAILING ADDRESS **701 W. Irene Pahrump, NV 89060**
 ADDRESS AT WELL LOCATION **701 W. Irene 36D 14.023N 116D 1.647W GPS WG584**

2. LOCATION **N/E** 1/4 **N/W** 1/4 Sec. **9** T **20S** N/S R **53E** E **Nye** County
 PERMIT NO. **35-161-39** Issued by Water Resources Parcel No. _____ Subdivision Name **Cal Vegas Ranchos**

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown loam	x	0	117	117
brown caleche	x	117	119	2
See next line	x	119	143	24
brown loam with caleche strings				
brown caleche with rock	x	143	147	4
brown loam	x	147	180	43

8. WELL CONSTRUCTION
 Depth Drilled **180** Feet Depth Cased **180+1** Feet

HOLE DIAMETER (BIT SIZE)
 From **11** Inches To **0** Feet **180** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	180

Perforations:
 Type perforation **sawcut**
 Size perforation **.188**

From **140** feet to **180** feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal **50**
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From **50** feet to **180** feet

9. WATER LEVEL
 Static water level **58** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **cool** °F Quality **good**

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Strickland Construction Co., Inc.** Contractor
 Address **5801 S. Homestead** Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board **40277**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**
 Signed *Jerry Strickland*
 By driller performing actual drilling on-site or contractor
 Date **4-16-08**

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift
 G.P.M. _____ Draw Down (Feet Below Static) _____ Time (Hours) _____

DCNR/DWR RECEIVED
 APR 18 2008
LAS VEGAS OFFICE