WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 105145
Permit No.
Basin 162

NOTICE OF INTENT NO. 32686

1. OWNER ALBERT SZENTIMREY
MAILING ADDRESS 1021 E FREMONT ST
PAHRUMP, NV

ADDRESS AT WELL LOCATION 1021 E FREMONT ST

2. LOCATION SW 1/4 NW 1/4 Sec. 14 T 21S N/S R 53E E NYE County
PERMIT NO. (Issued by Water Resources) 44-721-15 (Parcel No.) MESA OESTE ESTATES UNIT1 (Subdivision Name)

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
EXISTING 8" STEEL		160		
WELL			160	0
CLAY		160	170	10
CALICHE	WB	170	190	20
CLAY		190	210	20
CALICHE	WB	210	218	8
CLAY		218	224	6
CALICHE	WB	224	240	16
WGS84				
N 36 DEGREES 07.651				
WEST 115 DEGREES 59.530				

Date started 4/30/2008 , 19__
Date completed 4/30/2008 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR
RECEIVED
MAY 06 2008
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
EXISTING 8	Inches	0	Feet	160	Feet
7 7/8	Inches	160	Feet	240	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.36	.248	0	240

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3

From 140	feet to	160	feet
From 180	feet to	240	feet
From	feet to		feet
From	feet to		feet
From	feet to		feet

Surface Seal: [ ] Yes [X] No
Depth of Seal EXISTING
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 160 feet to 240 feet

9. WATER LEVEL
Static water level 123 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address 1220 E MANSE RD (Contractor)
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed (By driller performing actual drilling on-site or contractor)
Date 5/1/2008

USE ADDITIONAL SHEETS IF NECESSARY