

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61448

1. OWNER El Paso Corporation ADDRESS AT WELL LOCATION 1200 Americam Flatf
Mailing Address 2 North Nevada St., Colorado Virginia City NV
Springs, Co 80903

2. LOCATION NE $\frac{1}{4}$ ~~Sec~~ $\frac{1}{4}$ Sec. 6 T. 16 N/S R. 21 E. Lyon County
 PERMIT NO. NE Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
A 1 inch tremie pipe was set to 36 ft and neat cement was pumped to surface.				
casing was pulled and broken off at 9 ft of surface.				
the well was top off with neat cement to surface.				
<u>N 39,284734</u>				
<u>W 119,658962 NAD27</u>				
<u>PZ-1</u>				

8. WELL CONSTRUCTION
 Depth Drilled 37.15 Feet Depth Cased 37.15 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.5</u>	<u>PVC</u>			

Perforations:
 Type perforation _____
 Size perforation _____
 From 37.15 feet to 27.15 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 25 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 37 ft feet to 25 feet

9. WATER LEVEL
 Static water level 36 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 55 °F Quality poor

Date started 10/16, 2007
 Date completed 10/16, 2007

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

2007 NOV 26 AM 11:40

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Knoblock & Sons Pump and Supply Contractor
 Address 5425 Spanish Moss Sparks NV 89436 Contractor

Nevada contractor's license number 49162 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller AB-2213

Signed William J. [Signature]
 By driller performing actual drilling on site or contractor
 Date 11/13/2007