STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 105184
Permit No.
Basin Ø44

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60594

1. OWNER JOHN & BEV TUCKER
MAILING ADDRESS 3730 E. IDAHO STREET, SPACE 130
ELKO, NV 89801

ADDRESS AT WELL LOCATION COAL MINE CANYON ROAD
Subdivision Name: PARCEL OF LAND County: ELKO

2. LOCATION NW ¼ NW ¼ Sec 19 T 37N N/S R 57 E
PERMIT/WAIVER No. 006-561-007
Issued by Water Resources Parcel No.

Latitude 41.087379
Longitude 115.599492
UTM E 11T 0617634 [X] NAD 27
N 4549190 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVEL & SAND		0	20	20
CLAY & GRAVEL		20	45	25
CLAY & COBBLES		45	80	35
COBBLES		80	105	25
CLAY & COBBLES		105	135	30
GRAVEL		135	150	15
GRAVEL & CLAY		150	170	20
GRAVEL	175-200	170	200	30

Date started: 11-Oct , 20 07
Date completed: 12-Oct , 20 07

9. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	200

Perforations:
Type of perforation MACHINED MILL SLOT
Size of perforation 3/16" X 3", 6 ROW
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 5 to 50 [ ] Pumped [X] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 50 to 200 [ ] Pumped [X] Poured
Type: 3/8" PEA GRAVEL
Bentonite Chips: [ ] Yes [X] No to [ ] Pumped [ ] Poured
Type:

7. Water Level
Static water level: 66 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality:

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR LIFT	40		2

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC.
Contractor
Address P. O. BOX 850
Contractor
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2335
Signed David R Stone
By driller performing actual drilling on site or contractor
Date 10/17/2007

RECEIVED 2007 NOV 7 AM 10:29

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY