STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 105185
Permit No.
Basin 105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61010

1. OWNER VERUS CONSTRUCTION
MAILING ADDRESS 1615 HWY 395 NORTH
5W MINDEN, NV 89423

ADDRESS AT WELL LOCATION 1905 JANELLE CT
GARDNERVILLE, NV 89410
Subdivision Name: County: Douglas

2. LOCATION ~~NE~~ ¼ ~~SW~~ ¼ Sec 1 T 12N N/S R 20 E
PERMIT/WAIVER No. NE 1220-01-001-072
Issued by Water Resources Parcel No.

Latitude 38.93453°N
Longitude 119.68633°W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVER BURDEN		0	3	3
COBBLES		3	18	15
LARGE GRAVELS		18	63	45
SMALL GRAVELS		63	163	100
BROWN CLAY		163	187	24
FRACTURED GRAVELS	X	187	240	53

N 38.934629
W 119.685336 NAD27

Date started: 12-Nov, 20 07
Date completed: 15-Dec, 20 07

7. Water Level
Static water level: 86 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	35	3 HRS

9. WELL CONSTRUCTION
Depth Drilled 240' Feet Depth Cased 240' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	240	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
SDR 21	4.06	~~.216~~ .316	20	240

Perforations:
Type of perforation SAW CUT
Size of perforation 3 X 3/32
From 200 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☒ Cement Grout	0	to 100	☒ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ ≥30% Bentonite Grout		to	☐ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No 100 to 240 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING
Contractor
Address # 20 KIT KAT DRIVE
Contractor
CARTSON CITY, NV 89706
Nevada contractor's license number issued by the *State Contractor's Board* 0055548
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1905
Signed
By driller performing actual drilling on-site or contractor
Date 11/25/2007

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

RECEIVED
2007 NOV 27 AM 10:21
STATE ENGINEERS OFFICE