WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 105193
Permit No.
Basin 101

NOTICE OF INTENT NO. 59577

1. OWNER Gary Laca, David Pantell
MAILING ADDRESS 4700 Conrad Place Fallon NV 89406
ADDRESS AT WELL LOCATION 1870 W. Williams Ave Fallon NV 89406

2. LOCATION SW ¼ SW ¼ Sec. 25 T. 19 (N)/S R. 28 E. Churchill County
PERMIT NO. N/A E-000068 (Issued by Water Resources) 01-231-63 (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. MAT'L WELL TYPE MST
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other direct push

6. MW #3 LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown poor sand		0	0.5	0.5
brown silty sand		0.5	2.5	2
brown clayey sand		2.5	5	2.5
brown sandy clay		5	5.5	0.5
brown clayey sand		5.5	9	3.5
brown sandy clay		9	9.5	0.5
brown clayey sand	9.98	9.5	13	3.5
brown poor sand		13	25	12
N 39.476250				
W 118.798006 NAD27				
E-000068 tracking #				
WGS 84				
N 39° 28.569'				
W 118° 47.939'				

Date started 11 / 13 / 07 2007
Date completed 11 / 13 / 07 2007

7. N/A WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
4.5 Inches		0 Feet	25 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
sch	40		0	25

Perforations:
Type perforation slotted screened
Size perforation 0.010
From 15 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal (1-3) bentonite
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout (0-1) ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 3 feet to 25 feet

9. WATER LEVEL
Static water level 9.98 feet below land surface
Artesian flow N/A G.P.M. P.S.I.
Water temperature Warm °F Quality Murky

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Dale A. Lehman (Contractor)
Address 520 Edison Way (Contractor)
Reno NV 89502
Nevada contractor's license number issued by the State Contractor's Board C.E. 4186 (Pozzolla)
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1976
Signed Dale A. Lehman (By driller performing actual drilling on site or contractor)
Date 11 / 16 / 07

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627