TT16-MW10

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 1052160
Permit No.
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 54765

1. OWNER DEPT OF NAVY, NAS FALLON
MAILING ADDRESS 4755 Pasture Rd
ADDRESS AT WELL LOCATION 4755 Pasture Rd
Fallon, NV. 89496
Subdivision Name: NAS FALLON County: Churchill

2. LOCATION NE ¼ SW ¼ Sec 23 T 18 ☒ N/S R 29 E
PERMIT/WAIVER No. IRP
Issued by Water Resources
Parcel No. DD6-611-01
Latitude 39.408591
Longitude 118.696703
UTM E 1150353840 ☒ NAD 27
N 4363484 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILT SAND		0'	2'	2'
SAND		2'	5'	3'
SILT SAND		5'	10'	5'
CLAY, SILT		10'	11'	1'
SILT, SAND		11'	13'	2'

Date started: 11.8.07, 20 07
Date completed: 11.8.07, 20 07

9. WELL CONSTRUCTION
Depth Drilled 13' Feet Depth Cased 13' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8" Inches		0' Feet	13' Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		SCH. 40	0'	13'

Perforations:
Type of perforation Manufactured Slotted
Size of perforation .010
From 3' feet to 13' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0' to 1' ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 2½ to 13' ☐ Pumped ☒ Poured
Type: 2/16 Sand
Bentonite Chips: ☒ Yes ☐ No 1' to 2½ ☐ Pumped ☒ Poured
Type: 3/8 Bentonite chips

7. Water Level
Static water level: 7' feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Gregg Drilling (Contractor)
Address 950 Howe Rd (Contractor)
Martinez, CA 94553
Nevada contractor's license number issued by the *State Contractor's Board* C23-0038113
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-2328
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 11.8.07

(Rev. 05-05)

USE ADDITIONAL SHEETS IF NECESSARY

2007 DEC -3 PM 2:53