STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 105291
Permit No.
Basin 071

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60227

1. OWNER WE 3 LLC
MAILING ADDRESS 4016 Kietzke Ln Reno NV 89502

ADDRESS AT WELL LOCATION 4695 Cowboy Way
Winnemucca NV 89445
Subdivision Name: Sonoma Ranchos County: Humboldt

2. LOCATION SW ¼ ~~SW~~ ¼ Sec 7 T 35N N/S R 38 E
PERMIT/WAIVER No. SE 010-484-38
Issued by Water Resources Parcel No.

Latitude 40.917030 UTM E 437390 [x] NAD 27
Longitude 117.743503 N 4529601 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[x] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [x] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sand		0	5	5
cobbles		5	25	20
cobbles + gravel		25	65	40
gravel		65	85	20
cobbles + clay		85	105	20
fractured rock		105	145	40
fractured rock and clay		145	165	20
fractured rock	x	165	240	75

Date started: 27-Oct , 20 07
Date completed: 1-Nov , 20 07

9. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10.625	Inches	0	Feet	240	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625		0.188	+2	240

Perforations:
Type of perforation punched
Size of perforation 1.25 x 0.188
From 200 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [x] Yes [ ] No
[ ] Neat Cement to [ ] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[x] Concrete Grout 5 to 55 [ ] Pumped [x] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured
Gravel Pack: [x] Yes [ ] No 55 to 240 [ ] Pumped [x] Poured
Type: 3/8 minus
Bentonite Chips: [ ] Yes [ ] No to [ ] Pumped [ ] Poured
Type:

7. Water Level
Static water level: 182 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool °F
Quality: good

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [x] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	2	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name American Drilling & Pump Service
Contractor
Address 3040 Callahan St
Contractor
Winnemucca, NV 89445
Nevada contractor's license number issued by the *State Contractor's Board* 0020578
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2208
Signed Owen Bumbeckel
By driller performing actual drilling on site or contractor
Date 11/25/2007

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY