

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60142

1. OWNER Lucia Ramirez ADDRESS AT WELL LOCATION 2106 Alabama Ave  
 MAILING ADDRESS 2151 Pinion Rd  
Elko, NV 89801

2. LOCATION SE 1/4 SW 1/4 Sec. 12 T. 34 N. R. 55 E. Elko County  
 PERMIT NO. N/A Parcel No. 032-001-037 Subdivision Name Last Chance Ranch, Unit #3  
Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay, Sand, Gravel		0	5	5
Sandy clay		5	205	200
Gravel	xxx	205	235	30
Clay, sand, gravel		235	240	5
T.D. 240				
G.P.S.				
46.84059 N				
115.73188 W				
NAD 27				

8. WELL CONSTRUCTION  
 Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 50 Feet  
8 Inches 50 Feet 240 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>1</u>	<u>240</u>

Perforations:  
 Type perforation Torch cut  
 Size perforation \_\_\_\_\_  
 From 200 feet to 235 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 240 feet

9. WATER LEVEL  
 Static water level 65 feet below land surface  
 Artesian flow no G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature cold °F Quality excellent

Date started 12, 8 2007  
 Date completed 12-21 2007

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>10</u>	<u>1 hr</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Muth Drilling Co Contractor  
 Address 203 Pine St., Elko, NV 89801 Contractor

Nevada contractor's license number issued by the State Contractor's Board 10819  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 633

Signed James V. Muth  
 By driller performing actual drilling on site or contractor  
 Date 12-2