

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59140

1. OWNER Humboldt County ADDRESS AT WELL LOCATION East Thomas Canyon road  
 MAILING ADDRESS 50 W. Fifth St. Winnemucca NV. 89445

2. LOCATION SE 1/4 SW 1/4 Sec 12 T. 35 N. S. R. 37 E Humboldt County  
 PERMIT NO. m/φ 1427 Issued by Water Resources Parcel No. County right of way Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fine Silt	none	0'	2'	2'
Coarse Gravel + Silt	none	2'	15'	13'
Cobbles with Fine Sand	none	15'	20'	5'
Clay + Gravels	none	20'	25'	5'
Gravel w. H. Sand, Silt + Clay	none	25'	35'	10'
Orangeish fine sand + clay some gravel	none	35'	75'	40'
Fine sand + clay some gravel	none	75'	80'	5'
Brown clay + sand	none	80'	90'	10'
Brown fine sand + clay + gravel	none	90'	105'	15'
Orangeish brown sand + gravel	none	105'	140'	35'

Nothing 15,369,238

Easting 2,851,292

NAD 83

N 40.915254  
 W 117.764970 NAD27  
 5

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
 From 8 Inches To 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		Sch 40	0	110

Perforations:  
 Type perforation Factory Slot  
 Size perforation .020  
 From 110 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Placement Method:  Pumped  Poured 105 - 108 \* Portland cement

Gravel Packed:  Yes  No  
 From 108 feet to 140 feet

9. WATER LEVEL  
 Static water level 95.2' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature < 85°F Quality \_\_\_\_\_

Date started 1-15 2008  
 Date completed 1-17 2008

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Jason Adams (Haz-Tech Drilling) Contractor  
 Address P.O. Box 940 Meridian ID 83680 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0038018  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2246  
 Signed Jason Adams  
 By driller performing actual drilling on site or contractor  
 Date 1-21-08