STATE 1
CUST 1

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT 2 Nd
Original

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 105375
Permit No.
Basin Ø59

NOTICE OF INTENT NO. 59171

1. OWNER Bart + Donald Negro
MAILING ADDRESS P.O. Box 1237
Battle Mtn NV 89820

ADDRESS AT WELL LOCATION 1130-3300 E.
Subdivision Name:
County: Lander

2. LOCATION SE ¼ NW ¼ Sec 31 T 32 N/S R 46 E
PERMIT/WAIVER No. 011-250-26
Issued by Water Resources
Parcel No.

Latitude
Longitude
UTM E 514104 ☒ NAD 27
N 4494850 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5
Cleeche Clay		5	40	35
Sandy Clay		40	80	40
Tan Clay + Gravel		80	100	20
Tan Clay + Sand		100	120	—

RECEIVED
2007 APR 19 AM 10:52
STATE ENGINEERS OFFICE

N 40.606243
W 116.833291 NAD27

Date started: 03 - 19 , 20 07
Date completed: 03 - 20 , 20 07

7. Water Level
Static water level: 28 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100+	UNK	2 HRS

STATE ENGINEERS OFFICE
2007 OCT 18 AM 10:58
RECEIVED

9. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	120 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	120

Perforations:
Type of perforation Sawed
Size of perforation 3/10 X 1 1/2
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 4 to 55 ☐ Pumped ☒ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥80% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 90 to 120 ☐ Pumped ☒ Poured
Type: 1/4"
Bentonite Chips: ☒ Yes ☐ No 55 to 90 ☐ Pumped ☒ Poured
Type: Hole Plug

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name L B J Drilling Co.
Contractor
Address P.O. Box 902
Contractor
WMCA 89445
Nevada contractor's license number issued by the *State Contractor's Board* 9605
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1807
Signed Joe Bugatti
By driller performing actual drilling on site or contractor
Date 4-14-07

(Rev. 06-06)

USE ADDITIONAL SHEETS IF NECESSARY

Corrected by Joe