

STATO 1  
CUST 1

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

Well  
# 1

OFFICE USE ONLY  
Log No. 105378  
Permit No.  
Basin 070

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

59622

NOTICE OF INTENT NO.

1. OWNER Louis Kelly  
MAILING ADDRESS 5740 BIND LANE  
WINNEMUCA NV 89445  
2. LOCATION SE 1/4 SE 1/4 Sec 2 T 35 S R 37 E  
PERMIT/WAIVER No. 13-034-36  
Issued by Water Resources Parcel No.

ADDRESS AT WELL LOCATION 5880 BIND LANE  
J.B. ESTADOS  
Subdivision Name: HUMBOLDT County:  
Latitude 40.930713 UTM E 11434632 NAD 27  
Longitude 117.776414 N 4531144 NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	5	5
GRAVEL		5	20	15
SANDY CLAY		20	60	40
SANDY GRAVEL		60	80	20
PEA GRAVEL		80	100	20
SANDY CLAY		100	140	40
SAND & GRAVEL		140	180	40
GRAVEL		180	200	20

9. WELL CONSTRUCTION

Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>10 5/8</u>	<u>0</u>	<u>200</u>	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>		<u>.128</u>	<u>1</u>	<u>200</u>

Perforations:

Type of perforation SAND  
Size of perforation 3/6 X 2"

From 140 feet to 200 feet

Annular Seal:  Yes  No

Neat Cement to  Pumped  Poured

Cement Grout to  Pumped  Poured

Concrete Grout 5 to 55  Pumped  Poured

20% Bentonite Grout to  Pumped  Poured

Gravel Pack:  Yes  No 100 to 200  Pumped  Poured

Type: BAROID

Bentonite Chips:  Yes  No 55 to 100  Pumped  Poured

Type: BAROID

Date started: 4-13 2007  
Date completed: 4-14 2007

7. Water Level  
Static water level: 12 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature \_\_\_\_\_ °F  
Quality: Good

8. WELL TEST DATA

TEST METHOD	Bailer	Pump	Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<u>150</u>	<u>UNK</u>	<u>2 Hrs</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name: L.B.D. Drilling Co.  
Address: P.O. Box 902  
Winnemucca NV 89444

Nevada contractor's license number 9605  
issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1807

Signed: Jae Boss  
By driller performing actual drilling on site or contractor

Date: 4-25-07

USE ADDITIONAL SHEETS IF NECESSARY

Corrected Copy 6-13