

STATE 1  
CUST 1

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

Well # 2

OFFICE USE ONLY  
Log No. 105379  
Permit No. 59621  
Basin 070

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO.

1. OWNER LOUIS KOLLY  
MAILING ADDRESS 5740 BIND LANE  
WMCA NV 89445  
2. LOCATION SE 1/4 SW 1/4 Sec 2 T 25 N R 37 E  
PERMIT/WAIVER No. 113-055-11  
Issued by Water Resources Parcel No.

ADDRESS AT WELL LOCATION J.B. ESTATES  
5760 BIND LANE  
Subdivision Name: HUMBERT County:  
Latitude 40.931634 UTM E 1433977  NAD 27  
Longitude 117.785343 N 4531253  NAD 83 WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	5	5
Dry SAND		5	20	15
SAND + GRAVEL		20	80	60
GRAVEL + ROCKS		80	120	40
SAND + GRAVEL		120	140	20
GRAVEL		140	150	10

9. WELL CONSTRUCTION

Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>10 5/8</u>	<u>0</u>	<u>150</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>1.188</u>	<u>71</u>	<u>150</u>

Perforations:  
Type of perforation Torch CUT  
Size of perforation  
From 90 feet to 150 feet

Annular Seal:  Yes  No

<input type="checkbox"/> Neat Cement	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input checked="" type="checkbox"/> Cement Grout	<u>5</u> to <u>55</u>	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
<input type="checkbox"/> Concrete Grout	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> 20% Bentonite Grout	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured

Gravel Pack:  Yes  No 30 to 90  Pumped  Poured  
Type: ONE QUANTON INCH

Bentonite Chips:  Yes  No 60 to 90  Pumped  Poured  
Type: BARIOD

Date started: 4-18-07 20 07  
Date completed: 4-18-07 20 07

7. Water Level  
Static water level: 15 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: cold °F  
Quality: Good

8. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>100+</u>	<u>UNS</u>	<u>2</u>
<u>10:5 AM</u>	<u>22:00 PM</u>	<u>100Z</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name L B D Drilling Co. Contractor  
Address P.O. Box 902 Contractor  
WMCA NV 89445  
Nevada contractor's license number 9605  
issued by the State Contractor's Board  
Nevada driller's license number issued by the 1807  
Division of Water Resources, the on-site driller  
Signed Joe B...  
by driller performing actual drilling on site contractor  
Date 4-25-07

USE ADDITIONAL SHEETS IF NECESSARY

Corrected Copy 6-13