WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 105413
Permit No.
Basin 033A

NOTICE OF INTENT NO. 56103

1. OWNER Dan Hetrick
MAILING ADDRESS Box 36 Orovada NV 89425
ADDRESS AT WELL LOCATION N 41.521336 W 117.838537 NAD27

2. LOCATION SW ¼ NE ¼ Sec. 17 T. 42 N/S R. 37 E. Humboldt County
PERMIT NO. 29068 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☑ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☑ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil, Sand		0	50	
Sand Clay		50	95	
Gravel, Sand, Stringer Clay		95	155	
Soft Tan clay		155	165	
Gravel Sand		165	175	
Brown clay, DG stringers		175	195	
Gravel Sand		195	205	
Brown clay, DG stringer		205	355	
DG, Sand, Brown Clay		355	485	
Soft Brown Clay		485	495	
DG Sand		495	575	
Brown Clay, DG stringers		575	535	
Sand Gravel		535	545	
Brown Clay		545	575	
DG, Sand, Gravel		575	635	
Brown Clay		635	640	
N 41° 31.273				
W 117° 50.371 WGS 84				

Date started 11-12, 2007
Date completed 11-16, 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 640 Feet Depth Cased 640 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
28"	0	640

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16"		1/4	+1	640

Perforations:
Type perforation Double Row mill slot
Size perforation 1/4
From 120 feet to 640 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 0 feet to 640 feet

9. WATER LEVEL
Static water level 95 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ANS Enterprise (Contractor)
Address 399 Denio Hy 140 (Contractor)
Winnemucca NV 89445
Nevada contractor's license number issued by the State Contractor's Board 58683
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2140
Signed Ralph Schroder (By driller performing actual drilling on site or contractor)
Date 12-31-07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627