WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 105451
Permit No.
Basin 162

NOTICE OF INTENT NO. 32688

1. OWNER DAVE SUMNER
MAILING ADDRESS 1021 E CARSON
PAHRUMP, NV

ADDRESS AT WELL LOCATION 1021 E CARSON

2. LOCATION SW 1/4 NW 1/4 Sec. 14 T 21S N/S R 53E E NYE County
PERMIT NO. (Issued by Water Resources) 44-722-17 (Parcel No.) MESA OESTE ESTATES UNIT1 (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
8" STEEL WELL FROM				
0-140				
CLAY		140	145	5
CALICHE	WB	145	158	13
CLAY		158	175	17
CALICHE	WB	175	190	15
CLAY		190	220	30
CALICHE	WB	220	235	15
CLAY		235	256	21
CALICHE	WB	256	270	14
CLAY		270	280	10
WGS84				
N 36 DEGREES 07.536				
W 115 DEGREES 59.534				

DCNR/DWR
RECEIVED
MAY 2 7 2008
LAS VEGAS OFFICE

Date started 5/19/2008 , 19__
Date completed 5/19/2008 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 280 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
EXISTING 8	Inches	0 Feet	140 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
EXISTING 8	8" STEEL	.188	0	140
4.5	2.36	.248	140	280

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3
From 140 feet to 280 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal EXISTING
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 140 feet to 280 feet

9. WATER LEVEL
Static water level 126 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address 1220 E MANSE RD (Contractor)
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed (By driller performing actual drilling on-site or contractor)
Date 5/21/2008

USE ADDITIONAL SHEETS IF NECESSARY