

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 105462
Permit No. 75867
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER DIAMOND APEX, LLC
MAILING ADDRESS 7885 West Wind Rd
LAS VEGAS, NEV 89139

10500 Clark Peterson Blvd.
ADDRESS AT WELL LOCATION 8400 N I-15
LAS VEGAS, NEV.
Subdivision Name: _____ County: CLARK

2. LOCATION SW 1/4 NE 1/4 Sec 9 T 19 N S R 63 E
PERMIT/WAIVER No. 75867 | 122-09-410-001
Issued by Water Resources Parcel No. _____

Latitude 36° 18.833' N Longitude 114° 56.603' W
 NAD 27 NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE Commercial WELL TYPE
 Domestic Irrigation Test Cable Rotary RVC
 Municipal/Industrial Monitor Stock Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand & Gravel		0	300	300
FRACTURED Limestone		300	575	275
Limestone	X	575	725	150
CLAY		725	775	50
CAILCHE	X	775	850	75
CLAY		850	900	50
CAILCHE	X	900	990	90

9. WELL CONSTRUCTION

Depth Drilled 990 Feet Depth Cased 990 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>10 1/4</u>	0	990		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>F480</u>	<u>+1</u>	<u>990</u>

Perforations:
Type of perforation Saw cut
Size of perforation 1/8 x 4

From 880 feet to 960 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Annular Seal: Yes No

Neat Cement to _____ Pumped Poured
 Cement Grout to _____ Pumped Poured
 Concrete Grout to 60 Pumped Poured
 ≥30% Bentonite Grout to _____ Pumped Poured

Gravel Pack: Yes No to _____ Pumped Poured
Type: _____

Bentonite Chips: Yes No to _____ Pumped Poured
Type: _____

Date started: 2-22, 20 08
Date completed: 3-8, 20 08

7. Water Level
Static water level: 541 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: _____ °F
Quality: _____

8. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>100</u>		<u>1</u>

Stamp: DOWNHOLE RECEIVED
MAR 10 2008

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Redding Drilling Contractor
Address 530 E. Larsen Ln. Contractor
Henderson NV. 89044
Nevada contractor's license number 38155
issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2063

Signed Ron Terry
By driller performing actual drilling on site or contractor
Date 3-11-08

LAS VEGAS OFFICE