WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 105463
Permit No. 36459
Basin 170

NOTICE OF INTENT NO. 32747

1. OWNER Renoyer Farms
MAILING ADDRESS HC 61 Box 49 Alamo Nevada 89001
ADDRESS AT WELL LOCATION Renoyer Farms Two miles west of Rachel

2. LOCATION S/W ¼ N/E ¼ Sec. 33 T. 3 N/S R. 55 E. Lincoln County
PERMIT NO. 36459 Issued by Water Resources | 016-030-87 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
I believe this well had perforations all the way to bottom I could see them from surface to 80' and Records show this well pumped 500 gpm with only 40' of water in the well. Bailed this well with sand bailer to hard bottom of 156' removed approx 6 cubic feet of fine sand. Set 147' of 3" Tremmie pipe poured in slurry of 80 sacks cement 6 bags bentonite and 634 gals water pulled 3 Joints tremmie pipe, put in 2nd load of 68 bags cement 5 bags bentonite and 523 Gallons water Cement had only came up to 40' approx below surface put in another load of cement mixed same as second batch				
Total grout to fill well 216 bags cement, 16 bags bentonite, 1670 gals water. There must have been a large void from well pumping sand but I am confident we sealed the well properly.				
GPS 0653 84				
N 37° 38.764'				
W 115° 47.583'				

Date started 2-22-08, 20
Date completed 2-23-08, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DIGITIZED
RECEIVED
MAR 17 2008
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
[redacted] Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14		.250	0	157

Perforations:
Type perforation Factory
Size perforation 1/8" x 3"
From 0 feet to 156 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 110' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps (Contractor)
Address HC 61 Box 54 Hiko Nevada 89017 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0028866
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 2-25-08

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627