


033801

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 105465  
Permit No.  
Basin 213



PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33524

1. OWNER COUNTY OF CLARK LV. CON. AUTH. ADDRESS AT WELL LOCATION 364 CONVENTION CENTER DR, LAS VEGAS NV.  
MAILING ADDRESS 5008 GRAND CENTRAL PARK WAY LAS VEGAS NV.

2. LOCATION S.E. 1/4 S.E. 1/4 Sec 9 T 21 N/S R 61 E CLARK County  
PERMIT NO. 1102-09-703 604 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other  
4. PROPOSED USE  
 Domestic  Municipal/Industrial  Irrigation  Test  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other H.S.A.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
1 WELL - MW 1				
ASPHALT		0'	1.25'	1.25'
ALGEBRATE BASE		1.25'	1.0'	1.25'
SAND WITH GRAVEL		1.0'	3.0'	2.0'
BROWN CLAY WITH SAND		3.0'	8.5'	5.0'
CALICHE		8.5'	9.0'	1.5'
BROWN CLAY WITH SAND-GRAVEL		9.0'	30.0'	21.0'
CLAY WITH LAYERED CALICHE	YES	30.0'	35.0'	5.0'
FACILITY ID. NUMBER 8000814				
MAP DATUM WGS 84				
36.1387 N - 115.1591 W.				

8. WELL CONSTRUCTION

Depth Drilled 35 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)

From	To
8.5 Inches	0 Feet 35 Feet
Inches	Feet
Inches	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4		SCH 40	0	35

Perforations:  
Type perforation MACHINE SLOT  
Size perforation .020  
From 20 feet to 35 feet  
From feet to feet  
From feet to feet  
From feet to feet  
From feet to feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 18'  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 18.0 feet to 35 feet

9. WATER LEVEL  
Static water level 23.75 feet below land surface  
Artesian flow G.P.M. P.S.I.  
Water temperature °F Quality

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name EAGLE DRILLING Contractor  
Address 7150 PLACID ST. LAS VEGAS NV 89119 Contractor

Date started 4-7, 20 08  
Date completed 4-7, 20 08

7. WELL TEST DATA

TEST METHOD:	Bailer	Draw Down (Feet Below Static)	Draw Down (Feet Below Static) (Hours)

DCNR/DWR RECEIVED  
APR 16 2008  
LAS VEGAS OFFICE

Nevada contractor's license number issued by the State Contractor's Board 51266  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2357  
Signed Neil J. Winkler  
By driller performing actual drilling on site or contractor  
Date 4-10-2008