

MW 10

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 105474
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34945

1. OWNER COUNTY OF CLARK ADDRESS AT WELL LOCATION 364 CONVENTION CENTER Las Vegas NV
MAILING ADDRESS 5005 GRAND CENTRAL Pkwy Las Vegas NV 89155 Subdivision Name: County: CLARK

2. LOCATION SE 1/4 Sec 9 T 21 N R 61 E Latitude 36° 08' 00" UTM E NAD 27
PERMIT/WAIVER No. 162-09-703-007 Longitude 115° 09' 37" N NAD 83/WGS 84

3. WORKED PERFORMED: New Well, Replace, Recondition, Deepen, Other
4. PROPOSED USE: Domestic, Municipal/Industrial, Irrigation, Monitor, Test, Stock
5. WELL TYPE: Cable, Rotary, RVC, Other 8" IPSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
ASPHALT		0	3"	3"
GRAVEL SAND		3"	1'	4"
SILTY CLAY		1'	5"	4"
CEMENTED SAND & GRAVEL		5'	6'	1'
SANDY GRAVEL		6'	7'	1'
CEMENTED SAND GRAVEL		7'	8.6'	1.6'
CLAYEY GRAVEL		8.6'	14'	5.6'
SANDY CLAY GRAVEL		14'	19'	5'
SANDY CLAY		19'	25'	6'
SANDY CLAY GRAVEL		25'	32'	7'
CALICHE		32'	34'	2'

9. WELL CONSTRUCTION

Depth Drilled 34' Feet Depth Cased 34' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8" Inches	0'	34'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	PVC	5/8" 40	0'	34'

Perforations:

Type of perforation SLOTTED SLURRY
Size of perforation 0.020

From 19' feet to 34' feet

Annular Seal: Yes No

Neat Cement to Pumped Poured
 Cement Grout to Pumped Poured
 Concrete Grout 0' to 2' Pumped Poured
 ≥30% Bentonite Grout to Pumped Poured

Gravel Pack: Yes No 19' to 34' Pumped Poured
Type: 12 SILVER SAND
Bentonite Chips: Yes No 2' to 19' Pumped Poured
Type: 3/8 HOLE PLUG BAROLD

Date started: 5-5 20 08
Date completed: 5-5 20 08

7. Water Level
Static water level: 21.65 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down	Time (Hours)
DCNR/DWR RECEIVED MAY 19 2008 LAS VEGAS OFFICE		

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name: Timothy Thompson Contractor
Address: 750 PLOT ROAD SUITE F Las Vegas NV 89119 Contractor
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2097
Signed: [Signature] By driller performing actual drilling on site or contractor
Date: