STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 105535
Permit No.
Basin Ø66

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61269

1. OWNER Barrick Gold Exploration
MAILING ADDRESS 293 Spruce Road
Elko, NV 89801

ADDRESS AT WELL LOCATION 19 miles NE of Golconda
Hole #RMW3SE
Subdivision Name: County: Humboldt

2. LOCATION NW ¼ SW ¼ Sec 34 T 38N (N)/S R 42 E
PERMIT/WAIVER No. NEV2005102 Parcel No.
Issued by Water Resources

Latitude 41.124294
Longitude 117.238721
UTM E 479960.41 [x] NAD 27
N 4552370.32 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [x] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [x] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium & Clay		0	200	200
35 - 50 lb. bags of #8 sand				
45 - 50 lb bags of 3/8" hole plug				
27 - 94 lb bags of cement				

Date started: 10-Jan , 20 08
Date completed: 13-Jan , 20 08

9. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 198 ~~200~~ Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
14	Inches	0	Feet	20	Feet
8 3/4	Inches	20	Feet	200	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4		Sch 80	+2	198

Perforations:
Type of perforation Slotted
Size of perforation 0.02
From 158 feet to 198 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [x] Yes [ ] No
[x] Neat Cement 0 to 50 [ ] Pumped [x] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [x] Yes [ ] No 157 to 200 [ ] Pumped [x] Poured
Type: #8 Sand
Bentonite Chips: [x] Yes [ ] No 50 to 157 [ ] Pumped [x] Poured
Type: 3/8" Bentonite chips

7. Water Level
Static water level: 144 feet below land surface
Artesian Flow: No G.P.M. N/A P.S.I.
Water Temperature: Cool °F
Quality: Milky

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [x] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
6	56	30 min.

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Company, Inc. (Contractor)
Address PO Box 2748 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 0030823
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-2260
Signed Reese Schorl (By driller performing actual drilling on site or contractor)
Date 1/13/2008

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY