

003813
 PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33259

1. OWNER SCUMMER TRADING COMPANY ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 5015 333 E. CHARLSTON BLVD
BUENA PARK, CA. 90622-5015 LAS VEGAS NV
 2. LOCATION 6W 1/4 3W 1/4 Sec 34 T 20 NOR 61 E CLARK County
 PERMIT NO. R-1406 Issued by Water Resources Parcel No. 139-34-410-137 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other NSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
ASPHALT		0	3	3
TYPE II		3	1	17
Silty CLAY		1	5	4
CLAY		5	8.5	3.5
Silty CLAY	14	8.5	16	7.5
CLAY		16	22	6
Silty CLAY		22	33	11
CLAY		33	37	4

MAP DATUM W6884
PIW-2 36°09.538N 115°08.966W

FACILITY ID #
8-001049

8. WELL CONSTRUCTION
 Depth Drilled 37 Feet Depth Cased 35 Feet
 HOLE DIAMETER (BIT SIZE)
 From 1 1/2 Inches To 3.7 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.625</u>		<u>5040 PVC</u>	<u>35</u>	<u>0</u>

Perforations:
 Type perforation MAXIMUM SIZE
 Size perforation 2.020
 From 35 feet to 10 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 8 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 37 feet to 8 feet

9. WATER LEVEL
 Static water level 14 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 6/02, 2008
 Date completed 6/02, 2008

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EPIC DRILLING SERVICES LLC Contractor
 Address 7150 PACIFIC ST Contractor
LAS VEGAS NV 89119
 Nevada contractor's license number 51266
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 11-2272
 Division of Water Resources, the on-site driller.
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 6/09/08